

# 時延形

## 時延形漏電遮断器(最大動作時間0.45秒、慣性不動作時間0.1秒)

■時延形漏電遮断器は、漏洩電流検知から遮断まで一定の遅れ時間を持たせたものです。

■時延形漏電遮断器を上位遮断器として使用することにより、事故回路のみ遮断でき他回路への波及を防止できます。(漏電選択遮断)

適用定格電圧		100-200V(100/200V)の場合				200-415Vの場合			
適用器種	定格電圧	電流	100mA	200mA	感度切替形100/200/500mA	100mA	200mA	感度切替形100/200/500mA	
Eシリーズ(経済タイプ)	GBL-72EC	100-200V	75A	⑦	⑦				
	GBL-73EC	100-200V、200-415V	75A	●	●	○	●	●	⑦
	GBL-102EC	100-200V	50A						
			60A	●	●				
			75A	●	●				
			100A	●	●				
	GBL-103EC	100-200V、200-415V	50A	●	●		●	●	●
			60A	●	●	○	●	●	⑦
			75A	●	●	○	●	●	⑦
			100A	●	●	○	●	●	○
	GBL-122EC	100-200V	60A	●	●	●			
			75A	●	●	●			
			100A	●	●	●			
			125A	●	●	●			
	GBL-123ED	100-200V	120A	●	●	○			
			125A	●	●	○			
	GBL-123EC	200-415V	60A				●	●	⑦
			75A				●	●	⑦
			100A				●	●	⑦
			120A				●	●	○
125A						●	●	○	
GBL-152EC	100-200V	150A	●	●	●				
GBL-153EC	200-415V	150A				●	●	○	
		125A				●			
		150A				●			
		175A				●			
		200A				●			
GBL-222EA	100-200V	225A			●				
		125A						●	
		150A						○	
		175A						○	
		200A						○	
GBL-223EA	200-415V	225A						○	
		125A						○	
		150A						○	
		175A						○	
		200A						○	
GBL-253EA	200-415V	250A					○		
GBL-403EA	200-415V	250A				●	●	⑦	
		300A				●	●	○	
		350A				●	●	⑦	
		400A				●	●	○	
		30A	○						
GBUL-53・1KC	100/200V	40A	○						
		50A	○						
		60A	○						
GBUL-103・1KC	100/200V	75A	○						
		100A	○						
		60A				⑦			
GBUL-123・1EC	100/200V	75A				⑦			
		100A				○			
		120A				○			
		125A				○			
GBUL-153・1EC	100/200V	150A				○			
		125A				⑦			
		150A				⑦			
		175A				○			
GBUL-223・1EA	100/200V	200A				○			
		225A				○			
		250A				●			
		250A				●			
GBUL-253・1EA	100/200V	300A				●			
		350A				●			
		400A				●			
		250A				●			
		400A				●			

■動作時間は、0.15~0.45秒の間で動作します。

### 時延形漏電遮断器価格

■本体価格に下記価格をプラスしてください。■型式名はそれぞれGBL-、GBUL-となります。

適応器種	GB-72EC GB-73EC GBU-53・1KC	GB-102EC GB-103EC GBU-103・1KC	GB-122EC GB-123EC GBU-123・1EC	GB-152EC GB-153EC GBU-153・1EC	GB-222EA GB-223EA GBU-223・1EA	GB-253EA GBU-253・1EA	GB-403EA GBU-403・1EA
標準価格(円)	4,500	4,500	4,500	4,500	4,500	4,500	4,500

■Fシリーズ(高遮断容量)、Wシリーズ(定格電流可調整)については仕様一覧を参照 B-49ページ~、B-53ページ~