


	1	2	3	4	5	6	7	8	9	10	11	
A									漏電火災警報器 (EF) 用変流器			A
B												B
C												C
D												D
E												E
F												F
G												G
H												H
												
型式	S-20											
種類	貫通形											
設置場所	屋内用											
警戒電路	600V 50/60Hz 単/3相											
定格電流	50A											
貫通電線の最大外形	φ10mm×3本											
届出番号	Z040203A											
設計出力	26mV/50mA											
備考												
御納入先												
日付				受領印				数量				
承認	検	図	製	図	設	計						
				S-20								
年 月 日 三 角 法				K35-S20								
H26.5.20												
テンパール工業株式会社												